

VOC Content Test Certificate

Wednesday 13th October 2021

Supplier: SELLEYS Pty Ltd (1 Gow Street, PADSTOW, NSW, 2211, AUSTRALIA).

Sample Description: Selleys Wet Area Silicone

Date Tested: September 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B</p>	<p align="center">Selleys Wet Area Silicone</p>
<p>General Adhesives and Sealants limit: ≤50 grams per litre</p>	<p align="center">31 grams per Litre as VOC content per material</p>
<p align="center"><i>We hereby certify that Selleys Wet Area Silicone product is below the VOC Content limits of chosen categories specified by Green Building Council of Australia, Green Star Design & As Built, and Green Star Interiors</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

V2109066 A